



APPROVALS®

Certificate of Suitability

Addendum

Certificate No.: SAA151844

Date of Issue: 15 September 2015

Class Description: Non-Declared
Product Description: PV Grid-interactive Inverter

Additional Models	Description
iMars MG2KTL	Similar to iMars MG3KTL except rated input MPPT Range: 100-410Vdc, Max 450Vdc, Max 12A, I _{sc} : 13.2A and output Max 9A, Max 2000W.
iMars MG1K5TL	Similar to iMars MG3KTL except rated input MPPT Range: 80-410Vdc, Max 450Vdc, Max 10A, I _{sc} : 11A and output Max 6.5A, Max 1500W.
iMars MG1KTL	Similar to iMars MG3KTL except rated input MPPT Range: 60-400Vdc, Max 450Vdc, Max 9A, I _{sc} : 9.9A and output Max 4.5A, Max 1000W.
iMars MG750TL	Similar to iMars MG3KTL except rated input MPPT Range: 50-400Vdc, Max 400Vdc, Max 8A, I _{sc} : 8.8A and output Max 3.6A, Max 750W.


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 15-09-15 151844/2