



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA140073

Date of Issue: 24 December 2014

Class Description: Non-Declared
Product Description: PV Grid-interactive Inverter

General Modification:

Updated to comply with AS/NZS 3100:2009 Inc A1-3.

For model iMars BG30KTR:

Change of rating from MPPT range: 300-800Vdc to MPPT range: 280-800Vdc.

For model iMars BG25KTR:

Change of rating from MPPT range: 300-800Vdc to MPPT range: 280-800Vdc.

For model iMars BG20KTR:

Change of rating from:-

Isc PV: 29A x 2 to Isc PV: 27A x 2;

Max. continuous input current: 26A x 2 to Max continuous input current: 25A x 2;

MPPT range: 300-800Vdc to MPPT range: 280-800Vdc; and


Nominal AC voltage: 3N~ 400V to 3/N/PE, 230V/400V.

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-12-14 140073/3